



Certificate of Product Performance

Residential Boiler Heating Equipment

Certified Reference Number: 476335

Date Generated: 09/03/09

Status: Approved

This certificate serves as verification that the model cited below has been rated in accordance with applicable federal testing methods and verified by AHRI as capable of achieving the energy efficiency and performance ratings as tested within prescribed tolerances. This

certificate and these certified ratings ONLY apply to the specific model detailed below and are non-transferable to alternate models or configurations.

Manufacturer: TRIANGLE TUBE
Series: Prestige
Material: Stainless Steel
Location: Indoor
Model Number: Solo 60
Fuel Type: Natural Gas, Propane Gas
Input: 60.0 MBTUH
Heating Cap.: 54 MBTUH
PE: 53 Watts
Eae: 485 kWh/yr
Ef: 49.5 MMBTU/yr
AFUE: 95.0 %
Water: 47.00 MBTUH
CO2: 0.0 %
Ignition Type: Intermittent/Electronic Ignition
Draft Type: Induced Draft

Certified ratings for ARI, GAMA, and I=B=R certification programs are valid only for models and configurations listed in the AHRI Directory of Certified Product Performance located at www.ahridirectory.org and www.gamapower.org. The information for the model cited on this certificate can be located in the online directory by using the reference number on the certificate. AHRI

does not endorse the product(s) listed in this certificate and makes no representations, warranties or guarantees and assumes no responsibility for the product(s) listed in the certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s) or the unauthorized alteration of the data listed in this Certificate.

